

Sec. 24-179. - Fire hydrants.

Fire hydrants shall be installed and spaced throughout each subdivision when community water is available to maintain a at no greater than a 500 foot radius between hydrants. The location and spacing of hydrants shall be approved by the fire chief ~~of~~ having jurisdiction and the water authority having jurisdiction.

(Code 1999, § 152.095; Ord. No. 99-00-380, § 6.16, 4-4-2000)